

THE ONSITE PROGRAM REQUIRES A SEWER DETERMINATION WITH ALL APPLICATIONS. THIS REQUIREMENT IS TO ASSIST THE APPLICANT/OWNER AVOID DIFFICULTIES WITH A LOCAL SEWER AUTHORITY NOW OR IN THE FUTURE.

Both the Arizona Administrative Code and the Maricopa County Environmental Health Code have provisions where connection to a sewer collection system may be required.

The Maricopa County Environmental Health Code Chapter II, Section 8 Regulation 4 states:

- a. When connection may reasonably and practicably be made to an approved municipal, community, or similar sewerage system.....
- e. ...when an onsite wastewater treatment facility fails, ...

The Arizona Administrative Code R 18-9-A309 A. 5 states:

A person constructing a new on-site wastewater treatment facility or replacing the treatment works or disposal works of an existing on-site wastewater treatment facility shall connect to a sewage collection system **if**:

- a. **One** of the following applies:
 - i. A provision of a Nitrogen Management Area designated under R18-9-A317(C) requires connection;
 - ii. A county, municipal, or sanitary district ordinance requires connection; or
 - iii. The on-site wastewater treatment facility is located within an area identified for connection to a sewage collection system by a Certified Area-wide Water Quality Management Plan adopted under 18 A.A.C. 5 or a master plan adopted by a majority of the elected officials of a board or council for a county, municipality, or sanitary district; **or**
- b. A sewer line extension is available at the property boundary and both of the following apply:
 - i. The service connection fess is not more than \$6000 for a dwelling or \$10 times the daily design flow in gallons for a source other than a dwelling, and
 - ii. The cost of constructing the building sewer from the wastewater source to the service connection is not more the \$3000 for a dwelling or \$5 times the daily design flow for a source other than a dwelling.

NOTE: SOME MUNICIPALITIES HAVE STRINGENT REQUIREMENTS THAT MANDATE CONNECTION TO THE SEWAGE COLLECTION SYSTEM.

TO ASSIST YOU IN SEWER DETERMINATION, MARICOPA COUNTY ENVIRONMENTAL SERVICES IS PROVIDING CONTACTS, PHONE NUMBERS AND E-MAIL ADDRESSES ON THE FOLLOWING PAGE. A STATEMENT FROM THE LOCAL SEWER AUTHORITY INDICATING THEIR DETERMINATION OF CONNECTION OR NO CONNECTION TO THE SEWER IS ADVISED PRIOR TO ANY SUBMITTAL TO THE ENVIRONMENTAL SERVICES DEPARTMENT. MARICOPA COUNTY ENVIRONMENTAL SERVICES MAKES EVERY ATTEMPT TO PROVIDE ACCURATE INFORMATION. CONTACTS, PHONE NUMBERS AND E-MAIL ADDRESSES MAY CHANGE WITHOUT OUR KNOWLEDGE.

City	Sewer Availability Contact Information	Web/Email Address
AVONDALE	Michael Yracheta, Wastewater Collections Supervisor, 623-333-4414	myracheta@avondale.org
BUCKEYE	Leanne Makil Holbrook, CSR Utility Billing 623-349-6100	lholbrook@buckeyeaz.gov
CAVE CREEK	Jessica Marlow, PE, Utilities Manager, 480-488-6618,	jmarlow@cavecreek.org
CAREFREE	Black Mountain Sewer Company, 480-488-4152	www.libertywater.com
CHANDLER	Warren White, P.E. Principal Engineer 480-782-3337, fax 480-782-3350	warren.white@chandleraz.gov
EL MIRAGE	Dave Emon, Wastewater Superintendent, 623-876-4251	demon@cityofelmirage.org
GILBERT	Edgar Medina, PE, Interim Town Engineer, 480-503-6754	edgar.medina@gilbertaz.gov
GLENDALE	Mark Ivanich, Land Development Engineer, 623-930-3654	mivanich@glendaleaz.com
GOODYEAR	Engineering Office: Darren Farrar or Kevin Attebery, 623-882-3110	dfarrar@goodyearaz.gov kattebery@goodyearaz.gov
MESA	Beth Hughes-Ornelias, 480-644-3254	beth.hughes-ornelias@mesaaz.gov
PARADISE VALLEY	Richard Edwards, Senior Engineering Technician, 480-348-3528	redwards@paradisvalleyaz.gov
PEORIA	Rebecca Zook, Sr. Development Engineer, 623-773-7589	rebecca.zook@peoriaaz.gov
PHOENIX	Larry D. Valenzuela, 602 262-4035	larry.valenzuela@phoenix.gov
QUEEN CREEK	480-987-0496	www.queenecreek.org
SCOTTSDALE	Doug Mann, 480-312-5636	dmann@scottsdaleaz.gov
SURPRISE	James P. Shano, Utilities CIP – Division Manager, 623-222-7000	water@surpriseaz.com
TEMPE	Mark Weber, PE, Water Engineering Manager, 480-350-8526	mark_weber@Tempe.gov
TOLLESON	David L. Tyler, Superintendant Wastewater Utilities - (623) 478-8722	dtyler@Tollesonaz.org
WICKENBURG	Mark Lemon, Chief WWTP/WS/WD Operator, 928-684-5873	wwtp@ci.wickenburg.az.us